

RESOLUTION NO. 1905

A

ADOPTION OF ENGINEER'S REPORTS, AUTHORIZATION TO SECURE EASEMENTS, TO OBTAIN BIDS, AND TO ISSUE WARRANTS FOR CONSTRUCTION OF SS-77-6, OAK STREET (GEARY TO QUEEN).

BE IT RESOLVED that the reports of the City Engineer filed with the City Recorder on 9th day of August, 1977, concerning

SS-77-6, Oak Street (Geary to Queen)


be and the same are hereby adopted.

BE IT FURTHER RESOLVED that the Council authorize the Mayor and City Recorder to sign agreements on behalf of the City of Albany for the purpose of obtaining easements to construct the said improvements, direct the City Manager to obtain bids for the construction of said projects as required by law, and authorize the Mayor and City Recorder to make, issue and negotiate General Obligation Improvement Warrants for the performance of said improvements bearing interest not to exceed 6½% per annum and constituting General Obligations of the City of Albany. The terms of conditions of such warrants shall be as provided by ORS 287.502 to 287.510.


BE IT FURTHER RESOLVED that funds budgeted within the Improvement Fund be transferred as follows:

DR 026-99850-86001	\$14,312.39
CR 026-99850-89012	\$14,312.39

DATED this 14th day of September, 1977.

  
Mayor

ATTEST:

  
City Recorder

12  
1905

INTERDEPARTMENTAL MEMORANDUM  
Engineering Department

SUBJECT: Request for Public Hearing on SS-77-6, Oak Street - Geary to Queen

TO: Public Works Director

FROM: Civil Engineer

DATE: July 27, 1977                      REVISED: September 19, 1977

Project Description:

The Engineering Department has received a petition from some of the property owners in Oak Street between Geary and Queen, requesting sanitary sewer service. The petition represents approximately 25% of the proposed assessment area.

The project will begin at an existing 8-inch sanitary sewer at Oak and Geary and proceed down Oak Street for a distance of approximately 650 feet. Four inch and six inch laterals will be utilized for the adjacent lots.

After several public hearings on this project, the Engineering Department has revised the proposed location of the 8-inch sanitary sewer and will place it in the vicinity of the ditch on the south side of Oak Street. In addition, the assessable area for Tax Lot No. 300 has been decreased.

Summary of Costs:

1. Estimated Construction Cost	\$13,011.26
2. Contingencies 10%	<u>1,301.13</u>
3. Sub-total	\$14,312.39
4. E. L. A. 13%	1,860.61
5. T. V. Inspection	461.00
6. Warrant Inspection	<u>200.00</u>
7. Total Est. Assessable Cost	\$16,834.00

Cost per square foot =  $\$16,834.00 / 134,829 \text{ ft.}^2 = \$0.124854/\text{ft.}^2$

Method of Assessment:

It is recommended that the benefitting properties be assessed to a depth of 150 feet.

In determining the assessment area, consideration was given to those properties fronting Geary Street that were assessed to a depth of 150 feet for the construction of Geary Street Sanitary in 1973.

Respectfully submitted,

  
James Rankin  
Civil Engineer

aph

PROPOSED CHANGE WITH DECREASE IN ASSESSED FOOTAGE TO T.L. #300 and  
 LOCATING SANITARY SEWER IN ROAD-SIDE DITCH

PROPERTY AND ESTIMATED ASSESSMENT DATA

SS-77-6 Oak Street Sanitary Sewer, Geary to Queen

Revised August 9, 1977

NO.	OWNER AND ADDRESS	DESCRIPTION/TAX LOT NO.	ASSESSED SQ. FT.	EST. ASSESSMENT
1.	Rodney W. & Martha G. Tripp P. O. Box 747 Albany, OR 97321	11-3W-8CC T. L. 100	40,146	\$ 5,012.40 (+ 526.00)
2.	Rodney W. & Martha G. Tripp P. O. Box 747 Albany, OR 97321	11-3W-8CC T. L. 102	477	59.56 (+ 6.26)
3.	David C. Hayes 1200 E. Queen Avenue Albany, OR 97321	11-3W-8CC T. L. 300	(-37,016) 22,500	2,089.22 (-3,841.06)
4.	David C. Hayes 1200 E. Queen Avenue Albany, OR 97321	11-3W-8CC T. L. 401	23,279	2,906.49 (+ 305.31)
5.	Lena E. Burrelle 1910 S. Geary Street Albany, OR 97321	11-3W-8CC T. L. 400	28,374	3,542.62 (+ 372.13)
6.	Ben Freedman 2300 S. W. 6th Avenue Portland, OR 97208	11-3W-8CC T. L. 101	20,053	2,503.71 (+ 263.00)
<b>TOTALS</b>			(-37,016) 134,829	\$16,834.00 (-2,367.62)

Unit Cost = \$0.124854/sq. ft.

Changes in assessments are shown in parenthesis.

8

A  
#17#

PROPOSED CHANGE WITH DECREASE IN ASSESSED FOOTAGE TO T.I.L. #300 AND LOCATING SANITARY SEWER IN ROAD-SIDE DITCH

City of Alb. Engineering Dept.  
SS-77-6  
Oak Street Sanitary Sewer

7/20/77  
Revised 7/29/77

QUEEN AVENUE

GEARY STREET

RODNEY TRIPP  
TL 100

Ben Freedman  
TL 101

AREA  
PREVIOUSLY  
ASSESSED

OAK STREET

150'

150'

150'

8" Sewer

DAVID HAYES  
TL 300

DAVID HAYES  
TL 401

RODNEY TRIPP  
TL 102

TL 400  
LENA BURRELLE

North arrow pointing up and slightly left.

Handwritten mark resembling a lowercase 'b'.

Handwritten mark resembling '#17'.

