



CITY OF ALBANY, OREGON

FINANCE DEPARTMENT

ITB# 240106, Timber Linn Soccer Fields Improvements Phase 3

Invitation to Bid, Addendum 2

February 1, 2024

The purpose of this addendum is to modify the RFQ documents only to the extent indicated herein. All other areas not changed or otherwise modified by other addenda, shall remain in full force and effect. This addendum is hereby made an integral part of the original Project Documents.

1. The berm appears to be outside the area specified on appendix B. Please clarify the approximate area we are to be grading.

Answer: You can see the berm on the overhead photo (Appendix B). The grading area starts at the east side of the berm. Appendix B has been updated to reflect this.

2. **Bid Item #3 has been removed from the schedule of contract prices. Contractor should use the existing designs in Appendix A for planning purposes.**
3. What are the size, pressure and flow of the existing irrigation line?

Answer: The irrigation lines are 2" lines. We are running about 90 pounds of pressure from our lake pump. We do not have the gallons-per-minute flow information.